

SOP FOR RESERVOIR FILLING – TARBELA DAM PROJECT

Criteria for Normal Years

Reservoir Level (Feet)	Max Rate of Filling (Feet / day)
1500-1510	5.0 Ft / day (could be up to 10 Ft/day under special circumstances)
1510-1530	3.0 Ft / day
1530-1540	2.0 Ft / day
1540-1550	1.0 Ft / day

Criteria for Semi Water Short Years

Reservoir Level (Feet)	Max Rate of Filling (Feet / day)
1500-1510	5.0 Ft / day
1510-1530	3.0 Ft / day
1530-1550	2.0 Ft / day

Criteria for Water Short Years

Reservoir Level (Feet)	Max Rate of Filling (Feet / day)
1500-1530	5.0 Ft / day
1530-1550	2.0 Ft / day